

Form: **Addendum #1**
Project Title: **RFP 26-21 Air Filters (Reissue)**
Issued Date: **March 13, 2026**

#	Item	Description
1	Questions & Answers	Questions & Answers have been posted as part of this Addendum.

The information contained herein clarifies, revises, supplements and/or supersedes the specific parts of the documents referred to and shall be attached to and become part of those documents as if originally forming a part thereof. Except herein as modified, all other provisions of the documents shall remain in full force and, unless otherwise described in this Addendum, shall comply with the requirements originally specified. All other conditions of this project will remain in effect.

- Office of Procurement & Contracting: <https://stockton.edu/procurement-contracting/index.html>
- Please direct any questions to: RFP-Purchasing@stockton.edu

ADDENDUM ACKNOWLEDGMENT

I acknowledge that I have received and reviewed this Addendum

Company Name (please print)

Name (please print)

Signature

Date

THIS ACKNOWLEDGMENT PAGE MUST BE INCLUDED WITH SUBMISSION OR THE BID/PROPOSAL WILL BE REJECTED.

Questions & Answers

Question & Answer 1

Would a higher rated filter such as a MERV-10, be acceptable in place of the merv-8?

MERV10 would be acceptable, but please be mindful of the price difference.

Question & Answer 2

Do you know how many orders were placed last year per location?

We placed 4 orders last year. All orders are received at Central Receiving, University staff distributes them from here.

Question & Answer 3

Are there loading docks at all locations?

All orders are received at Central Receiving. There is a loading dock as well as forklifts to assist with delivery.

Question & Answer 4

How many ship to locations are there?

All orders are received at Central Receiving

If you submitted questions to RFP-Purchasing@stockton.edu by the due date indicated in the project document, but they were not received and answered here, please contact:

Regina Rosenello
Office of Procurement & Contracting
Regina.Rosenello@stockton.edu
609.626.6079